



Annex D1

Data sheet template

CONTENTS

- 1 Air/Water heat pumps
- 2 Heat pumps for Domestic Hot Water (DHW)

Certificate data	
Certificate holder name	Daikin Europe N.V.
Address	Zandvoordestraat 300. 8400 Oostende Belgium
Type of heat pump	Air/Water
Reg. No.	011-1W0096
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH
Name of testing laboratory	CETIAT



Annex D1

Data sheet template

Air/water heat pumps

	EHSX04P30B / ERLQ004C*V3	EHSXB04P30B / ERLQ004C*V3
	HPSU Compact 304 / RRLQ004C*V3	HPSU Compact 304 Biv / RRLQ004C*V3
General data		
Refrigerant	R-410A	R-410A
Mass of refrigerant [kg]	1.5	1.5
GWP according to EU Nr. 517/2014 [CO2eq]	2,087.5	2,087.5
Frequency [Hz]	50	50
Voltage [V]	230	230
Test points EN 14511-2 Air/Water heat pump		
A7/W35		
heat output [kW]	4.53	4.53
El input [kW]	0.87	0.87
COP	5.23	5.23
A7/W55		
heat output [kW]	3.69	3.69
El input [kW]	1.27	1.27
COP	2.90	2.90

Test points EN 14511-4		
operating Range A/W... lower limit-lower limit (min)		
Please state if the requirement is passed or failed	Passed	Passed
operating Range A/W... upper limit- upper limit (min)		
Please state if the requirement is passed or failed	Passed	Passed
Shutting off the heat transfer medium flow		
Please state if the requirement is passed or failed	Passed	Passed
Complete power supply failure		
Please state if the requirement is passed or failed	Passed	Passed
Defrost test only for AirT Water heat pumps (if applicable)		
Please state if the requirement is passed or failed	n/a	n/a

Average Climate Medium temperature application		
Declared values EN 14825		
Tbiv [°C]		
heat output [kW]	4.2	4.2
El input [kW]	2.07	2.07
COP	2.03	2.03
Sound power level according EN 12102		
Sound power level indoor if relevant [dB(A)]	39	39
Sound power level outdoor [dB(A)]	61	61
Declared data regarding ErP regulation		
η_s	132	132
Prated [kW]	5	5
SCOP	3.38	3.38
Declared capacity for heating for part load at indoor temperature 20 °C and outdoor temperature Tj		
Pdh: Tj = - 7 °C [kW]	4.2	4.2
COPd: Tj = - 7 °C	2.03	2.03
Pdh: Tj = +2 °C [kW]	2.6	2.6
COPd: Tj = + 2 °C	3.31	3.31
Pdh: Tj = +7 °C [kW]	1.8	1.8
COPd: Tj = + 7 °C	4.43	4.43
Pdh: Tj = +12 °C [kW]	2.2	2.2
COPd: Tj = + 12 °C	6.55	6.55
Pdh: Tj = bivalent temperature [kW]	4.2	4.2
COPd: Tj = bivalent temperature [kW]	2.03	2.03
Pdh: Tj = - 15 °C (if TOL < - 20 °C) [kW]	n/a	n/a
COPd: Tj = - 15 °C (if TOL < - 20 °C)	n/a	n/a
Tbiv [°C]	-7	-7
TOL [°C]	-10	-10
WTOL [°C]	55	55
Annual energy consumption QHE [kWh]	2,934	2,934
Power input „compressor off“ [kW] (if applicable)	n/a	n/a
P _{OFF} [W]	11	11
P _{TO} [W]	43	43
P _{SB} [W]	11	11
P _{CK} [W]	0.0	0.0
P _{SUP} [W]	0.7	0.7
Type of energy input (e.g. electricity)	Electrical	Electrical

Heat pumps for Domestic Hot Water (DHW)

	EHSX04P30B / ERLQ004C*V3	EHSXB04P30B / ERLQ004C*V3
	HPSU Compact 304 / RRLQ004C*V3	HPSU Compact 304 Biv / RRLQ004C*V3
General data		
Refrigerant	R-410A	R-410A
Mass of refrigerant [kg]	1.5	1.5
GWP	2,087.5	2,087.5
Frequency [Hz]	50	50
Voltage [V]	230	230
Off-peak product (yes/no)	Yes	Yes
Technical data – average climate		
Declared load profil	L	L
Efficiency η_{dhw} in %	103	103
Heating up time h:min	01:40	01:40
Standby power input W	40.22	40.22
Reference hot water temperature °C	45.6	45.6
Mixed water at 40°C	155	155
Sound power level indoor if relevant [dB(A)]	39	39
Sound power level outdoor [dB(A)]	61	61