

date 24.01.2025

DATASHEET

Reg. No. **011-6T0020**

(filled in by DIN CERTCO)

Thermostatic radiator valves according to DIN EN 215

Certificate Holder **Zhejiang Changfei Fluid Intelligent Control Co., Ltd.** **ID 84**

Street, number Xuanmen Industrial City Economic Development Zone Yuhuan

Postal code / City 317608 Zhejiang

Country People's Republic of China

Head **No. 005 (THED100001 / RV1934)**

Type Liquid Head with integral sensor

Hysteresis C 0,50 K Differential pressure influence D 0,50 K

Response time Z 23 min. Water temperature effect W 0,40 K

Control accuracy CA 0,60 K

Head **No. 012**

Type Liquid Head with integral sensor

Hysteresis C 0,60 K Differential pressure influence D 0,40 K

Response time Z 23 min. Water temperature effect W 0,85 K

Control accuracy CA 0,60 K

Valve(s)	Series	Form ¹	Size	Nominal flow rate ²
----------	--------	-------------------	------	--------------------------------

1 Form: L – Angle T – Straight

2 Nominal flow rate $q_{n,NH}$ in kg/h: declared by the manufacturer

CF5003 * T DN 15 155
(RADV100001 / RV1335-1/2)

CF5004 * L DN 15 175
(RADV100010 / RV1336-1/2)

CF5005 * T DN 15 155

CF5006 * L DN 15 155

CF5007 * L DN 15 155

CF5008 * L DN 15 155

CF5011 * L DN 15 170