

date 30.01.2025

DATASHEET

Reg. No. **011-6T0021**

(filled in by DIN CERTCO)

Thermostatic radiator valves according to DIN EN 215

Certificate Holder	ZHEJIANG BAIYILUN INTELLIGENT CONTROL SYSTEM CO.,LTD.	ID 86
---------------------------	--	--------------

Street, number No.3 Building, No.322 Jinhai Avenue, Xinghai Street, Wenzhou

Postal code / City 325000 Wenzhou, Zhejiang

Country People's Republic of China

Head	BYL-AD
-------------	---------------

Type	Liquid	Head with integral sensor	
Hysteresis C	0,35 K	Differential pressure influence D	0,20 K
Response time Z	22 min.	Water temperature effect W	1,10 K
Control accuracy CA	0,60 K		

Head	BYL-V002
-------------	-----------------

Type	Liquid	Head with integral sensor	
Hysteresis C	0,24 K	Differential pressure influence D	0,10 K
Response time Z	16 min.	Water temperature effect W	0,60 K
Control accuracy CA	0,20 K		

Valve(s)	Series	Form ¹	Size	Nominal flow rate ²
----------	--------	-------------------	------	--------------------------------

1 Form: L – Angle T – Straight
2 Nominal flow rate $q_{n, NH}$ in kg/h: declared by the manufacturer

BYL-J017	*	L	DN 15	160
BYL-Z018	*	T	DN 15	160