

DATASHEET

Reg. No. **011-6T0024**

(filled in by DIN CERTCO)

Thermostatic radiator valves according to DIN EN 215

Certificate Holder	Zhuhai Edison Smart Home CO., LTD	ID 61			
Street, number	Doumen District				
Postal code / City	519170 Zhuhai City				
Country	People's Republic of China				
Head	IDC-H02				
Type	Liquid	Head with integral sensor			
Hysteresis C	0,45 K	Differential pressure influence D	0,20 K		
Response time Z	22 min.	Water temperature effect W	1,10 K		
Control accuracy CA	0,60 K				
Head	IDC-H06				
Type	Liquid	Head with integral sensor			
Hysteresis C	0,45 K	Differential pressure influence D	0,20 K		
Response time Z	23 min.	Water temperature effect W	1,20 K		
Control accuracy CA	0,60 K				
Valve(s)	Series	Form¹	Size	Nominal flow rate²	
1 Form:	L – Angle	T – Straight			
2 Nominal flow rate $q_{n,NH}$ in kg/h:	declared by the manufacturer				
IDC-V09	GB	L	DN 15	200	
IDC-V31	S	T	DN 10	135	
IDC-V32	S	L	DN 10	135	
IDC-V33	S	T	DN 15	135	
IDC-V34	S	L	DN 15	135	
IDC-V35	S	T	DN 20	135	
IDC-V36	S	L	DN 20	135	