

date 21.03.2025

D A T A S H E E T

Reg. No. **011-6T0039**

(filled in by DIN CERTCO)

Thermostatic radiator valves according to DIN EN 215

Certificate Holder	Wolseley UK Limited		ID 90	
Street, number	2 Kingmaker Court			
Postal code / City	CV34 6DY, Warwick			
Country	United Kingdom			
Head	256552/256553/256554			
Type	Liquid	Head with integral sensor		
Hysteresis C	0,50 K	Differential pressure influence <i>D</i>	0,25 K	
Response time Z	20 min.	Water temperature effect <i>W</i>	0,40 K	
Control accuracy CA	0,60 K			
Head	256555			
Type	Liquid	Head with integral sensor		
Hysteresis C	0,50 K	Differential pressure influence <i>D</i>	0,25 K	
Response time Z	20 min.	Water temperature effect <i>W</i>	0,40 K	
Control accuracy CA	0,60 K			
Head	256556/256557			
Type	Liquid	Head with integral sensor		
Hysteresis C	0,50 K	Differential pressure influence <i>D</i>	0,20 K	
Response time Z	20 min.	Water temperature effect <i>W</i>	1,20 K	
Control accuracy CA	0,60 K			
Valve(s)	Series	Form ¹	Size	Nominal flow rate ²
1 Form: 2 Nominal flow rate <i>q</i> _{n NH} in kg/h:	L – Angle declared by the manufacturer	T – Straight		
19.42021.R15	GB	L	DN 15	190
19.52011.R15	GB	T	DN 15	160