





Summary of	EN12977-3	HEAT STORE test results	Licence Number	011-7S2535 T				
Annex to Solar KEYMARK Certificate			Issued	2015-11-20				
Company	Vaillant GmbH		Country	Germany				
Brand (optional)	Vaillant		Website	www.vaillant.com				
Street	Berghauser Strasse 40		E-mail	info@vaillant.com				
Postal Code	42859	Remscheid	Tel. / Fax	+49	(0)2191-180			
Solar heat store - general description								
Application(s)			Hot water					
Direct solar loop / heat exchanger			Internal heat exchanger					
Direct hot water loop / heat exchanger			Direct					
Internal auxiliary heating (I)			Internal heat exchanger	Internal auxiliary heating (II)		None		
Store location options			Indoor only	Store geometri		Vertical cylinder		
Heat store parameters and test results								
Parameter		Source ¹	Unit	VH S1 150/4 B	VH S1 250/4 B	VH S2 250/4 B	VH S1 350/4 B	VH S2 350/4 B
Weight	Weight of the unit (empty) incl. insulation	M	kg	67.7	90.7	104.5	129.2	135.0
Size	Gross height of unit incl. insulation	M*	mm	1064	1539	1539	1700	1700
	Gross width incl. insulation	M*	mm	600	600	600	700	700
	Gross depth incl. insulation	M*	mm	600	600	600	700	700
Volumes	Nominal - total	M*	litres	162	254	246	335	330
	Effective - total (out of simulation)	L	litres	161	264	264	367	367
	Auxiliary heated volume (I)	L	litres	-	-	106	-	147
	Auxiliary heat exchanger	M*	litres	-	-	5.6	-	4.6
	Solar loop heat exchanger	M*	litres	8.9	8.9	8.9	10.4	10.4
Insulation	Thickness on top	M	mm	30...115	30...115	30...115	70...150	70...150
	Thickness on sides	M	mm	50	50	50	75	75
	Thickness on bottom	M	mm	30...164	30...164	30...164	20...100	20...100
Others	Max. operation pressure (solar loop)	M	kPa	6	6	6	6	6
	Max. operation pressure (hot water)	M	kPa	10	10	10	10	10
	Max. operation pressure (space heating)	M	kPa	-	-	10	-	10
	Max. operation temperature (solar loop)	M	°C	120	120	120	120	120
	Material of store (water enclosure part)	M	-	enamelled steel				
Corrosion protection	M	-	Magnesium anode					
Notes	¹ Source of information		L: Laboratory test result	M: Manufacturers information				
Testing Laboratory	TÜV Rheinland Energie und Umwelt GmbH							
Website	http://www.tuv.com/st							
Test report id. number	21227422.002							
Date of test report	2015-11-20							
Comments of test lab laboratoire				 Genau. Richtig. TÜV Rheinland Energie und Umwelt GmbH Am Grauen Stein 51105 Köln				
The electrical auxilliary heater is included into the pump unit and connected to the solar heat exchanger! The Types VH S1 150/4 B and VH S2 250/4 B were fully tested according to EN 12977-3.								




Summary of	EN12977-3	HEAT STORE test results	Certification No.	011-7S2535 T				
Annex to Solar KEYMARK Certificate			Issued	2015-11-20				
Company	Vaillant GmbH		Country	Germany				
Brand (optional)	Vaillant		Website	www.vaillant.com				
Street	Berghauser Strasse 40		E-mail	info@vaillant.com				
Postal Code	42859	Remscheid	Tel. / Fax	+49	(0)2191-180			
Measured thermal parameters								
Parameter	Source ¹	Unit	VH S1 150/4 B	VH S1 250/4 B	VH S2 250/4 B	VH S1 350/4 B	VH S2 350/4 B	
Thermal parameters	Total effective thermal capacity	L	kJ/K	668.039	1095.42	1095.42	1522.8	1522.8
	Thermal capacity of aux. heated part I	L	kJ/K	-	-	439.827	-	609.948
	Thermal capacity of aux. heated part II	L	kJ/K	-	-	-	-	-
	Stand-by heat loss rate	L	W/K	1.67	1.82	1.82	2.15	2.15
	Effective vertical heat conductivity	L	W/(m*K)	1.7	2.33	2.33	2.33	2.33
	Stratification number (during discharge)	L	-	70	97	97	97	97
	UA-value, solar heat exchanger at mean temperature difference at mass flow	L	W/K	148	177	177	320	320
		L	K	10	10	10	10	10
		L	[kg/h]	100	200	200	300	300
	UA-value, hot water heat exchanger at mean temperature difference at mass flow	L	W/K	-	-	-	-	-
		L	K	-	-	-	-	-
		L	[kg/h]	-	-	-	-	-
	UA-value, space heat exchanger at mean temperature difference at mass flow	L	W/K	-	-	-	-	-
		L	K	-	-	-	-	-
L		[kg/h]	-	-	-	-	-	
UA-value, auxiliary heat exchanger at mean temperature difference at mass flow	L	W/K	-	-	182	-	224	
	L	K	-	-	20	-	20	
	L	[kg/h]	-	-	900	-	900	
Notes	¹ Source of information		L: Laboratory test result	M: Manufacturers information				
Testing Laboratory	TÜV Rheinland Energie und Umwelt GmbH							
Website	http://www.tuv.com/st							
Test report id. number	21227422.002							
Date of test report	2015-11-20							
Comments of test lab laboratoire			 Genau. Richtig. TÜV Rheinland Energie und Umwelt GmbH Am Grauen Stein 51105 Köln					
No comments								



Summary of	EN12977-3	HEAT STORE test results	Certification No.	011-7S2535 T
Annex to Solar KEYMARK Certificate			Issued	2015-11-20
Company	Vaillant GmbH		Country	Germany
Brand (optional)	Vaillant		Website	www.vaillant.com
Street	Berghauser Strasse 40		E-mail	info@vaillant.com
Postal Code	42859	Remscheid	Tel. / Fax	+49 (0)2191-180

Schematic drawing(s) of heat store (showing positions of inlets, outlets, heat exchangers, sensors etc.)



Parameter		Source ¹	Unit	VIH S1 150/4 B	VIH S1 250/4 B	VIH S2 250/4 B	VIH S1 350/4 B	VIH S2 350/4 B	
Relative	Cold water inlet	L	%	20	5	5	22	22	
positions of inlets, outlets, sensors and other inserts in the store - all related to the indicated reference point	Hot water outlet	L	%	100	100	100	100	100	
	Collector loop inlet	L	%	80	56	56	44	44	
	Collector loop outlet	L	%	14	15	15	12	12	
	Space heating inlet	L	%	-	-	-	-	-	
	Space heating outlet	L	%	-	-	-	-	-	
	Auxiliary heating inlet	L	%	-	-	100	-	98	
	Auxiliary heating outlet	L	%	-	-	59	-	66	
	Lower point of electrical heater	L	%	-	-	-	-	-	
	Temp. sensor 1	Auxilliary heater	L	%	-	-	59	-	61
	Temp. sensor 2	Optional info on usage	L	%	-	-	-	-	-
	Temp. sensor 3	Optional info on usage	L	%	-	-	-	-	-
	Temp. sensor 4	Optional info on usage	L	%	-	-	-	-	-
	Temp. sensor 5	Optional info on usage	L	%	-	-	-	-	-
	Temp. sensor 6	Optional info on usage	L	%	-	-	-	-	-
Reference point for all positions above		L	inner bottom of tank						
Notes	¹ Source of information		L: Laboratory test result	M: Manufacturers information					

Testing Laboratory	TÜV Rheinland Energie und Umwelt GmbH
Website	http://www.tuv.com/st
Test report id. number	21227422.002
Date of test report	2015-11-20