



	Heat Pump KEYMARK	 TÜVRheinland®  Genau. Richtig.
Annex D1 Data sheet template		Rev.-No.: 1 Date: 14.12.2015 Page: 1 of 7

Data has to be declared for all Models inside a sub-type.

1. AIR/WATER; BRINE/WATER; WATER/WATER HEAT PUMPS (IF APPLICABLE) **2**
2. EXHAUST AIR HEAT PUMPS (IF APPLICABLE) FEHLER! TEXTMARKE NICHT DEFINIERT.
3. HEAT PUMPS FOR DOMESTIC HOT WATER (DHW) (IF APPLICABLE) FEHLER! TEXTMARKE NICHT DEFINIERT.



Certificate data	
Certificate holder name	Stiebel Eltron GmbH & Co. KG
Address	Dr.-Stiebel-Straße 33, 37603 Holzminden Germany
Type of heat pump	Air/Water
Reg. No.	011-1W00031
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH
Name of testing laboratory	VDE Prüf- und Zertifizierungsinstitut

	Heat Pump KEYMARK	 TÜVRheinland® DIN CERTCO Genau. Richtig.
Annex D1 Data sheet template		Rev.-No.: 1 Date: 14.12.2015 Page: 2 of 7



1. Air/Water; Brine/Water; Water/Water heat pumps (if applicable)

	WPL 57		
General data			
Refrigerant	R407 C		
Mass of refrigerant [kg]	7,5		
GWP according to EU Nr. 517/2014 [CO _{2eq}]	13,305		
Frequency [Hz]	50		
Voltage [V]	400		
Test points EN 14511-2 Air/Water heat pump (if applicable)			
A7/W35			
heat output [kW]	31,01		
El input [kW]	8,64		
COP	3,59		
A7/W55 (if applicable)			
heat output [kW]	29,91		
El input [kW]	11,22		
COP	2,67		
Test points EN 14511-2 Brine/Water heat pump (if applicable)			
B0/W35			
heat output [kW]			
El input [kW]			
COP			
B0/W55			
heat output [kW]			
El input [kW]			
COP			
Test points EN 14511-2 Water/Water heat pump (if applicable)			
W10/W35			
heat output [kW]			
El input [kW]			
COP			
W10/W55			
heat output [kW]			
El input [kW]			
COP			



In case of gas driven heat pump, EN14511 shall be replaced by EN 12309:2015-03

	Heat Pump KEYMARK	 TÜVRheinland® DIN CERTCO Genau. Richtig.
Annex D1 Data sheet template		Rev.-No.: 1 Date: 14.12.2015 Page: 3 of 7



Test points EN 14511-4			
operating Range A.../W... lower limit-lower limit (min)			
Please state if the requirement is passed or failed	passed		
operating Range A.../W... upper limit- upper limit (min)			
Please state if the requirement is passed or failed	passed		
Shutting off the heat transfer medium flow			
Please state if the requirement is passed or failed	passed		
Complete power supply failure			
Please state if the requirement is passed or failed	passed		
Defrost test only for AirT Water heat pumps (if applicable)			
Please state if the requirement is passed or failed	passed		

	Heat Pump KEYMARK	 TÜVRheinland® DIN CERTCO Genau. Richtig.
Annex D1 Data sheet template		Rev.-No.: 1 Date: 14.12.2015 Page: 4 of 7



Average Climate Low temperature application (if applicable)			
Declared values EN 14825			
T_{biv} [°C]	T_{biv} at low temperature conditions		
heat output [kW]	25,1		
El input [kW]	8,59		
COP	2,92		
Sound power level according EN 12102			
Sound power level indoor if relevant) [dB(A)]	-		
Sound power level outdoor [dB(A)]	(see 55°C applications)		
Declared data regarding ErP regulation			
η_s	134		
P_{rated} [kW]	31		
SCOP	3,43		
Declared capacity for heating for part load at indoor temperature 20 °C and outdoor temperature T_j			
Pdh: $T_j = - 7$ °C [kW]	23,8		
COPd: $T_j = - 7$ °C	2,73		
Pdh: $T_j = +2$ °C [kW]	29,6		
COPd: $T_j = + 2$ °C	3,51		
Pdh: $T_j = +7$ °C [kW]	30,7		
COPd: $T_j = + 7$ °C	3,89		
Pdh: $T_j = +12$ °C [kW]	33,8		
COPd: $T_j = + 12$ °C	4,47		
Pdh: $T_j =$ bivalent temperature [kW]	25,1		
COPd: $T_j =$ bivalent temperature	2,92		
Pdh: $T_j = - 15$ °C (if $TOL < - 20$ °C) [kW]	18,6		
COPd: $T_j = - 15$ °C (if $TOL < - 20$ °C)	2,13		
T_{biv} [°C]	-5		
TOL [°C]	-20		
WTOL [°C]	60		
Annual energy consumption Q_{HE} [kWh]	18713		
Power input „compressor off“ [W]	0		
P_{OFF} [W]	7		
P_{TO} [W]	7		
P_{SB} [W]	7		
P_{CK} [W]	49		
P_{SUP} [kW]	9,15		
Type of energy input (e.g. electricity)	electricity		

	Heat Pump KEYMARK	 TÜVRheinland® DIN CERTCO Genau. Richtig.
Annex D1 Data sheet template		Rev.-No.: 1 Date: 14.12.2015 Page: 5 of 7

Average Climate Medium temperature application (if applicable)			
Declared values EN 14825			
T_{biv} [°C]			
heat output [kW]	26,4		
El input [kW]	11,84		
COP	2,23		
Sound power level according EN 12102			
Sound power level indoor (if relevant) [dB(A)]	-		
Sound power level outdoor [dB(A)]	69		
Declared data regarding ErP regulation			
η_s	100		
P_{rated} [kW]	33		
SCOP	2,57		
Declared capacity for heating for part load at indoor temperature 20 °C and outdoor temperature T_j			
Pdh: $T_j = -7$ °C [kW]	25,1		
COPd: $T_j = -7$ °C	2,13		
Pdh: $T_j = +2$ °C [kW]	31,1		
COPd: $T_j = +2$ °C	2,54		
Pdh: $T_j = +7$ °C [kW]	28,7		
COPd: $T_j = +7$ °C	2,89		
Pdh: $T_j = +12$ °C [kW]	29,3		
COPd: $T_j = +12$ °C	3,49		
Pdh: $T_j =$ bivalent temperature [kW]	26,4		
COPd: $T_j =$ bivalent temperature	2,23		
Pdh: $T_j = -15$ °C (if $TOL < -20$ °C) [kW]	19,7		
COPd: $T_j = -15$ °C (if $TOL < -20$ °C)	1,84		
T_{biv} [°C]	-5		
TOL [°C]	-20		
WTOL [°C]	60		
Annual energy consumption Q_{HE} [kWh]	26254		
Power input „compressor off“ [W] (if applicable)	0		
P_{OFF} [W]	7		
P_{TO} [W]	7		
P_{SB} [W]	7		
P_{CK} [W]	49		
P_{SUP} [kW]	9,54		
Type of energy input (e.g. electricity)	electricity		

	Heat Pump KEYMARK	 TÜVRheinland® DIN CERTCO Genau. Richtig.
Annex D1 Data sheet template		Rev.-No.: 1 Date: 14.12.2015 Page: 6 of 7

Warmer Climate (if applicable)			
Declared values EN 14825 – 35°C application			
T_{biv} [°C]			
heat output [kW]	29,9		
El input [kW]	9,2		
COP	3,25		
Sound power level according EN 12102			
Sound power level indoor (if relevant) [dB(A)]	-		
Sound power level outdoor [dB(A)]	(see 55°C applications)		
Declared data regarding ErP regulation			
η_s	150		
P_{rated} [kW]	30		
SCOP	3,82		
Declared capacity for heating for part load at indoor temperature 20 °C and outdoor temperature T_j			
$P_{dhT_j = -7\text{ °C}}$ [kW]	23,9		
$COP_{d T_j = -7\text{ °C}}$	2,69		
$P_{dhT_j = +2\text{ °C}}$ [kW]	29,9		
$COP_{d T_j = +2\text{ °C}}$	3,25		
$P_{dh T_j = +7\text{ °C}}$ [kW]	30,3		
$COP_{d T_j = +7\text{ °C}}$	3,62		
$P_{dh T_j = +12\text{ °C}}$ [kW]	33,1		
$COP_{d T_j = +12\text{ °C}}$	4,32		
$P_{dh T_j = \text{bivalent temperature}}$ [kW]	29,9		
$COP_{d T_j = \text{bivalent temperature}}$	3,25		
$P_{dh T_j = -15\text{ °C (if } TOL < -20\text{ °C)}}$ [kW]	18,6		
$COP_{d T_j = -15\text{ °C (if } TOL < -20\text{ °C)}}$	2,15		
T_{biv} [°C]	2		
TOL [°C]	2		
WTOL [°C]	60		
Annual energy consumption Q_{HE} [kWh]	10460		
Power input „compressor off“ [W] (if applicable)	0		
P_{OFF} [W]	7		
P_{TO} [W]	7		
P_{SB} [W]	7		
P_{CK} [W]	49		
P_{SUP} [kW]	0		
Type of energy input (e.g. electricity)	electricity		

	Heat Pump KEYMARK	 TÜVRheinland® DIN CERTCO Genau. Richtig.
Annex D1 Data sheet template		Rev.-No.: 1 Date: 14.12.2015 Page: 7 of 7

Colder Climate (if applicable)			
Declared values EN 14825 – 35°C application			
$T_{biv}/^{\circ}\text{C}$			
heat output [kW]	21,6		
El input[kW]	8,21		
COP	2,63		
Sound power level according EN 12102			
Sound power level indoor if relevant) [dB(A)]	-		
Sound power level outdoor [dB(A)]	(see 55°C applications)		
Declared date regarding ErP regulation			
η_s	120		
P_{rated} [kW]	32		
SCOP	3,09		
Declared capacity for heating for part load at indoor temperature 20 °C and outdoor temperature T_j			
Pdh: $T_j = - 7^{\circ}\text{C}$ [kW]	23,6		
COPd: $T_j = - 7^{\circ}\text{C}$	2,89		
Pdh: $T_j = +2^{\circ}\text{C}$ [kW]	29,4		
COPd: $T_j = + 2^{\circ}\text{C}$	3,75		
Pdh: $T_j = +7^{\circ}\text{C}$ [kW]	31,0		
COPd: $T_j = + 7^{\circ}\text{C}$	4,05		
Pdh: $T_j = +12^{\circ}\text{C}$ [kW]	33,7		
COPd: $T_j = + 12^{\circ}\text{C}$	4,45		
Pdh: $T_j =$ bivalent temperature [kW]	21,6		
COPd: $T_j =$ bivalent temperature	2,63		
Pdh: $T_j = - 15^{\circ}\text{C}$ (if $TOL < - 20^{\circ}\text{C}$) [kW]	18,5		
COPd: $T_j = - 15^{\circ}\text{C}$ (if $TOL < - 20^{\circ}\text{C}$)	2,19		
T_{biv} [°C]	-10		
TOL [°C]	-20		
WTOL [°C]	60		
Annual energy consumption Q_{HE} [kWh]	25263		
Power input „compressor off“ [W] (if applicable)	0		
P_{OFF} [W]	7		
P_{TO} [W]	7		
P_{SB} [W]	7		
P_{CK} [W]	49		
P_{SUP} [kW]	31,64		
Type of energy input (e.g. electricity)	electricity		