

date 03.04.2023

DATASHEET

Reg. No. **011-6T0025**

(filled in by DIN CERTCO)

Thermostatic radiator valves according to DIN EN 215

Certificate Holder	Taizhou Jiaheng Valves Co. Ltd.	ID 66
---------------------------	--	--------------

Street, number Chumen Town, Yuhuan Country

Postal code / City 317605 Zhejiang

Country People's Republic of China

Head	TL.10
-------------	--------------

Type Liquid Head with integral sensor

Hysteresis C 1,00 K Differential pressure influence *D* 1,00 K

Response time Z 27 min. Water temperature effect *W* 1,50 K

Control accuracy CA 1.00 K

Valve(s)	Series	Form ¹	Size	Nominal flow rate ²
----------	--------	-------------------	------	--------------------------------

1 Form: L – Angle T – Straight
 2 Nominal flow rate $q_{n,NH}$ in kg/h: declared by the manufacturer

R.31	*	L	DN 15	190
------	---	---	-------	-----

R.32	*	T	DN 15	170
------	---	---	-------	-----