

date 06.09.2024

DATASHEET

Reg. No. **011-6T0040**

(filled in by DIN CERTCO)

Thermostatic radiator valves according to DIN EN 215

Certificate Holder	Wolseley UK Limited			ID 90	
Street, number	2 Kingmaker Court, Warwick Technology Park				
Postal code / City	CV34 6DY, Warwick				
Country	United Kingdom				
Head	205765/205766/205767/205768/205770/205771				
Type	Liquid	Head with integral sensor			
Hysteresis C	0,60 K	Differential pressure influence D			0,15 K
Response time Z	28 min.	Water temperature effect W			0,80 K
Control accuracy CA	0,60 K				
Valve(s)	Series	Form ¹	Size	Nominal flow rate ²	
1 Form: 2 Nominal flow rate $q_{n,NH}$ in kg/h:	L – Angle declared by the manufacturer		T – Straight		
C04059H063B	GB	L	DN 15	180	
Head	205769/205772				
Type	Liquid	Head with integral sensor			
Hysteresis C	0,60 K	Differential pressure influence D			0,15 K
Response time Z	28 min.	Water temperature effect W			0,80 K
Control accuracy CA	0,60 K				
Valve(s)	Series	Form ¹	Size	Nominal flow rate ²	
1 Form: 2 Nominal flow rate $q_{n,NH}$ in kg/h:	L – Angle declared by the manufacturer		T – Straight		
CL04017H002B4	*	T	DN 15	120	
Head	205773/205774				
Type	Liquid	Head with integral sensor			
Hysteresis C	0,50 K	Differential pressure influence D			0,15 K
Response time Z	28 min.	Water temperature effect W			0,90 K
Control accuracy CA	0,60 K				
Valve(s)	Series	Form ¹	Size	Nominal flow rate ²	
1 Form: 2 Nominal flow rate $q_{n,NH}$ in kg/h:	L – Angle declared by the manufacturer		T – Straight		
C04059H063B	GB	L	DN 15	180	

Head	205775/205776			
Type	Liquid	Head with integral sensor		
Hysteresis C	0,50 K	Differential pressure influence D	0,15 K	
Response time Z	28 min.	Water temperature effect W	0,90 K	
Control accuracy CA	0,60 K			
Valve(s)	Series	Form ¹	Size	Nominal flow rate ²
1 Form: 2 Nominal flow rate $q_{n\text{ NH}}$ in kg/h:	L – Angle declared by the manufacturer	T – Straight		
CL04017H002B4	*	T	DN 15	120