

date 18.03.2021

DATASHEET

Reg. No. **011-6T0041**

(filled in by DIN CERTCO)

Thermostatic radiator valves according to DIN EN 215

Certificate Holder	STH Westco Limited		ID 91	
Street, number	Unit C6, William Way, Moss Industrial Estate St Helens Road			
Postal code / City	WN7 3PT / Leigh / Lancashire			
Country	United Kingdom			
Head	UW05957			
Type	Liquid	Head with integral sensor		
Hysteresis C	0,25 K	Differential pressure influence D	0,50 K	
Response time Z	24 min.	Water temperature effect W	0,50 K	
Control accuracy CA	0,20 K			
Head	UW05513			
Type	Liquid	Head with integral sensor		
Hysteresis C	0,55 K	Differential pressure influence D	0,45 K	
Response time Z	22 min.	Water temperature effect W	0,60 K	
Control accuracy CA	0,60 K			
Valve(s)	Series	Form¹	Size	Nominal flow rate²
1 Form:	L – Angle	T – Straight		
2 Nominal flow rate $q_{n,NH}$ in kg/h:	declared by the manufacturer			
YK101A-15J-SB/550U	F	L	DN 15	200

1 Form: L – Angle T – Straight
2 Nominal flow rate $q_{n,NH}$ in kg/h: declared by the manufacturer

DIN CERTCO • Alboinstraße 56 • 12103 Berlin

Tel: +49 30 7562-1131 • Fax: +49 30 7562-1141 • E-Mail: info@dincertco.de • www.dincertco.de